

CABINET FOR HEALTH SERVICES  
DEPARTMENT FOR PUBLIC HEALTH  
ON SITE SEWAGE DISPOSAL SYSTEMS  
SITE EVALUATION

County Bullitt Application No. 645943  
Owner's Name Miller Enterprises Lot Address Lot 4 Tanglewood Hills  
Applicant's Name Dustin Miller Address \_\_\_\_\_

Evaluation Factors	Proposed System Area	Alternative Area 1
1. Topography (slope %)	3-4% (S) PS U	S PS U
2. Landscape Position	Side Slope Convex (PS) U	S PS U
3. Soil Texture and Group	0-5" siL Group III (S) 5-42" siCL Group III (PS) U	S PS U
4. Soil Structure	Blocky to 28" (S) PS U	S PS U
5. Internal Soil Drainage	No mottling less than Chroma 2 0-42" (S) PS U	S PS U
6. Soil Depth (in.)	42" depth (S) PS U	S PS U
7. Restrictive Horizons (in.)	Prismatic Pan @ 28" (S) PS U	S PS U
8. Available Space	100% Repair (S) PS U	S PS U
9. Overall Site Classification	S PS U	S PS U
10. Soil Series (if available)		

S = SUITABLE PS = PROVISIONALLY SUITABLE U = UNSUITABLE

11. List site and/or system modifications or alternatives required for site approval and the specific area selected for system installation: Install one 1,000 gal septic tank

Option: Install 270' of 3' wide Leaching Chambers at 10" depth with 12" of settled topsoil of group III or better.  
or  
Install 345' of 3' wide rock bed at 10" depth with 12" of settled topsoil of group III or better.  
\* Option 2 may only be used if installation depth and slope permit.

FILLED OR DISTURBED SITES ONLY

12. Percolation Test Required: Yes  No

13. Percolation tester instructions: Test to be run in flagged area at depth of \_\_\_\_\_ in. Presoaking of test holes to be in accordance with Section 6. (4) ( ) Test measurements to be conducted in accordance with Section 6. (5) ( ).

Attach copy of application and site plan. Draw in evaluation areas and designate area selected for system installation (flagged area).

Date Requested 3-27-14 Start \_\_\_\_\_ A.M. \_\_\_\_\_ P.M. Chad Lynch G-1-720  
Date Completed \_\_\_\_\_ End \_\_\_\_\_ A.M. \_\_\_\_\_ P.M. Bullitt \_\_\_\_\_  
County or District Health Department

